



SIDEWALK NOTES:

1. CONCRETE SHALL BE 3000 PSI MINIMUM.
2. CONTROL JOINT REQUIRED AT 5' O.C. FOR SIDEWALKS OR AS SHOWN ON THE PLANS.
3. CONTROL JOINTS SHALL BE 1/8" THICK AND 1" DEEP.
4. EXPANSION JOINT MATERIAL REQUIRED @ 20' O.C. FOR SIDEWALKS OR AS SHOWN ON PLANS.
5. DO NOT CROSS REINFORCEMENT THRU EXPANSION JOINT.
6. PROVIDE EXPANSION JOINT MATERIAL WHERE SIDEWALKS MEET, EXISTING SIDEWALKS AND CURBS.

DETAIL NO.

114



CITY OF EL PASO
PARKS & RECREATION

DETAIL NAME

SIDEWALK

NTS